SWA	SWMS No 011 SJD Electrical Job Safety Analysis / Safe Work Method Statement								Page 1 of 6				
SJD ELECTRICAL PTY LTD - ABN 53 127 802 608 - ACN 127 802 608 - ELECTRICAL LICENCE 68608 - QBCC LICENCE 1270514 - ARC LICENCE AU19801 - MOLEX LICENCE C										X LICENCE CIAU3372			
Safe Work Method Statement Title: SWMS: 011 INSTALLATION OF SUBMAINS									Date Created: 00/00/16				
Pro	ject Name:				Person responsible	Review Date: 00/00/17							
Pro	ject/Client:				Job No:		Authorised I	Зу:		Revision No. 0			
			Licences, Pe	rmits, Comp	etencies Requi	ired: (tick items	s relevant to this	task and site)					
□ Со	onfined Space	_ \ \	Work at Heights		□ Excavation		□ Hot Work		□ Radia	tion			
□ W	hite Card		EWP		□ Electrical Lice	ense	□ Rescue and	I Resuscitation	□ Netwo	ork Access			
			Comr	non Hazards	to Manage: (tid	ck items releval	nt to this task an	d site)					
□ Ma	anual handling	_ \ \	Working at Heigh	nts	□ Risk of Electr	ic Shock	□ Slips, Trips	and Falls	□ Housekeeping				
HAZA	ARD CLASSIFICATION MATRIX	(Probability				Eliminat	tion 🗖			
POSS	SIBLE RESULTS		RARE	UNLIKELY	POSSIBLE	LIKELY	ALMOST CERTAIN						
Risk	= Consequence x Likelihood			С	D	Е		Substitu					
se	Catastrophic		Medium (M)	High (H)	High (H)	Extreme (E)	Extreme (E)		Isolati	on			
Consequences	Major		Medium (M)	Medium (M)	High (H)	High (H)	Extreme (E)		Enginee	ring /			
nbe	Moderate	3	Low (L)	Medium (M)	High (H)	High (H)	High (H)		Admi	n			
suc	Minor	2	Low (L)	Low (L)	Medium (M)	Medium (M)	High (H)		, terrin	PPE IS THE 'LAST LINE OF DEFENCE"			
ပိ	Insignificant	1	Low (L)	Low (L)	Low (L)	Medium (M)	Medium (M)		РРЕ				
	RISK RATING				ACTION REQUIRED (ALARP – As Low As Reasonably Practicable)								
E = E	xtreme, UNACCCEPTABLE									ision that risk is ALARP			
H = H	igh risk, Only acceptable if ALAR	Р			to reduce risk to an acceptable level. Activity must not continue until the level of risk is reduced to As Low As Reasonably bly Medium rating. Operations Manager and/or Project Supervisor approval of the risk controls is required.								
			existing risk controls and additional management actions to reduce the risk to ALARP and preferably Low rating . Activity his Manager and/or Project Supervisor approval.										
L = Low risk, Tolerable Tolerable risk. Carry out activity													
Ba: PPE be u	to		FACE SHIELD MUST BE WORN	SAFETY VEST MUST BE WORN	RESP	ACE MASK BRATOR BE WORN			PROTECTION ST BE WORN	FALL AREST EQUIPMENT MUST BE WORN			

✓ app

Other PPE:

SJD Electrical Job Safety Analysis / Safe Work Method Statement

Safe Work Method Statement Title: SWMS: 011 INSTALLATION OF SUBMAINS

Job Task #	Job Step	Potential Health, Safety and Environmental Hazards	PROBABILITY	CONSEQUENCE	RATING	Control Measures	PROBABILITY	CONSEQUENCE	RATING	PERSON(S) RESPONSIBLE
1	Planning and preparation	Non-compliance with current legislative requirements and company processes.	D	4	Н	All personnel to complete site specific induction. All personnel to have completed company specific induction. Personnel are to hold the required licenses and certificates for the work, and be assessed as competent to use or operate equipment and plant. All personnel must read, understand and sign off on this SWMS. All personnel are given the opportunity to provide input into the content of this SWMS. Daily pre-starts will be held at the beginning of each shift. Any changes throughout the shift will be communicated prior to the commencement of the next task. A JSA is to be completed for any changes to the task. Ensure permit requirements are understood.	В	4	М	Work crew Supervisor Permit Holder
		Working outdoors with exposure to; - UV / high temperatures causing heat stress / dehydration / sunburn - Fauna and insects causing bites and stings Interactions with other trades working in the vicinity;	D	3	Н	'Check ins' during extreme weather conditions. Comply with the Queensland Worksafe heat stress procedure. Ensure there is an area in the shade for rest (preferably Crib Facilities). Work Breaks are compulsory at nominated times (preferably during the hotter parts of the day) Drink adequate water amount of water. Use sun block for protection from sun. Use insect repellent (if applicable). Ensure other workers are informed and aware of all other trades working in the area.	В	3	L	Work crew
		 Inadvertently cause hazardous situation including trips, slips, falls 				working in the area Communicate potential interactions during prestart				Work Crew

Job Task #	Job Step	Potential Health, Safety and Environmental Hazards	PROBABILITY	CONSEQUENCE	RATING	Control Measures	PROBABILITY	CONSEQUENCE	RATING	PERSON(S) RESPONSIBLE
		Unauthorized access to work area by other authorized personnel without correct PPE.	D	H Follow all site rules and procedures. Wear all mandatory PPE and task specific PPE. If a hazard is identified in the work area – fix it immediately or if unable to do so, isolate the hazard and inform your supervisor immediately. Site wide barricading to be installed to restrict access to unauthorized personnel. Signage to be visible around all site and at all access points. All visitors must report to site office before entering site. All visitors to be escorted by a site inducted personnel member.		В	3	Σ	Supervisor Work crew	
		Poor ground conditions Uneven, loose, wet or soft ground at the work site.	С	2	н	Inspect path of travel for any obstructions and remove them. Daily site inspections prior to commencement of work activities and at the conclusion of each work day. Regular housekeeping inspections including regular walk rounds to be conducted to ensure a clean and tidy work area.	В	2	Δ	Work crew
2	Work area preparation	Personal injury - - Cuts, strains, abrasions, burns - Possible eye injury - Dust inhalation (depends on surrounds – these tasks should not cause dust or fumes)	С	3	Н	Authority and empowerment to Stop the Job. Follow all site rules and procedures. Ensure correct manual handling techniques are followed. Wear all mandatory PPE and task specific PPE. Communicate task clearly with all work crew members. Ensure a thorough understanding of expectations. If a hazard is identified in the work area – fix it immediately or if unable to do so, isolate the hazard and inform you supervisor. Work on flat surface where practicable Secure all tools and/or equipment by lanyard or store in a toolbox/basket when on the work platform.	В	3	М	Work crew Supervisor

Job Task #	Job Step	Potential Health, Safety and Environmental Hazards	PROBABILITY	CONSEQUENCE	RATING	Control Measures	PROBABILITY	CONSEQUENCE	RATING	PERSON(S) RESPONSIBLE
3	Check location to drawings and specification layout and mark out	Personal injury due to contact with live parts	С	4	Н	Obtain work approval and confirm any client site/safety instruction. Check scope of works to confirm whether work be re-scheduled so it may be isolated. Confirm with client that works meet the requirements regarding work on energised equipment and apparatus and the risk of harm would be greater if the circuits were de-energised before work commenced. Confirm that person/s carrying out the work are appropriately qualified, competent, confident and trained for the task.	В	4	М	Work crew Supervisor
4	Plan installation so as to work towards the main switchboard.	Personal injury - - Cuts, strains, abrasions, burns - Possible eye injury - Dust inhalation (depends on surrounds – these tasks should not cause dust or fumes) Unauthorized access to work area by other authorized personnel without correct PPE.	С	4	н	Identify the electrical equipment to be worked on and the appropriate points of supply Isolate the equipment from sources of supply if possible. Secure the isolation by such means as lock-out to prevent inadvertent reenergisation and attached a danger tag Prove that the exposed conductors are de-energised (i.e. 'test for dead') Working persons shall confirm rescue procedures and have attended confined space rescue training.	В	4	М	Work crew Supervisor
5	Confirm cable specifications / condition and install cabling	Defective installation causing electrocution.	С	4	Н	Ensure appropriate test equipment is being used Appropriate tools for the job are available Ensure all appropriate barricading is in place to isolate the area Working kits are used and maintained, and first check operation of test apparatus. Visual inspection shall include; - Basic protection (protection against direct contact with live parts) - Fault protection (protection against indirect contact with exposed conductive parts) - Protection against hazardous parts (guarding/screening) - Protection against spread of fire (fire blanket / fire extinguisher) - General condition of equipment.	В	4	М	Work crew Supervisor
6	Completion of task	Slips, trips, and falls	С	4	н	Leave work area tidy. Store equipment in authorised access area (e.g. locked storage facility) Report any damage/defect to supervision and tag out any faulty equipment.	В	4	М	Work crew

SJD Electrical Job Safety Analysis / Safe Work Method Statement

Safe Work Method Statement Title: SWMS: 011 INSTALLATION OF SUBMAINS

Personnel Qualifications and	Personnel Duties a	Training Required to Complete Work						
Experience Required	Supervisor	All Personnel	Training Required to Complete Work					
Personnel will need to be trained and confident.	Empower all personnel to STOP the JOB if required to do so.	All personnel to maintain tidy work area on site at all times. Personal Protective Equipment (PPE) to be worn at all times on site.	Supervisor to be trained in risk identification, assessment and control e.g. Job Safety Analysis (JSA).					
Appropriate industry and site specific induction.	Supervisor to carry out daily inspections of work site for hazards.	Ensure housekeeping is maintained throughout the task to avoid the risk of injury.	Electrician to be trained in hazard identification, Risk Level and control.					
Must be a Licensed Electrician to carry out the works.	Ensure appropriate permits are in place for the task (if applicable).	Barricading to be used as appropriate to protect others from working below elevated work.	Safety observer who is competent to perform the task being observed and is also competent in electrical rescue and cardio-pulmonary resuscitation (CPR).					

Engineering Details / Certificates / Australian Standards	Referenced – Codes of Practice / Regulations / Legislation
 ASNZS 3000 Wiring Rules AS/NZS 3012:2010 Electrical Installations – Construction and Demolition Sites. AS/NZS 3017 - Electrical installations - verification guidelines AS/NZS 4836 Safe working on or near low voltage electrical installations and equipment 	 Work Health and Safety Act and Regulations 2011 Electrical Safety Act 2002 and Electrical Safety Regulations 2013 Electrical Safety Code of Practice 2013 - Managing Electrical Risks in the Workplace Hazardous Manual Tasks Code of Practice 2011 Managing risks of Plant in the workplace Code of Practice 2013
Plant / Equipment Required (Mobile or Static)	Maintenance Checks / Calibration Intervals
 Portable hand tools, electrical power tools / drills (insulated tools) May require scissor lift, boom lift or cherry picker (refer to Scissor Lift / Boom Lift / Cherry Picker SWMS) Appropriate testing equipment 	 Hand tools and ladders to be checked daily. All electrical equipment to be tested and tagged.

SJD Electrical Job Safety Analysis / Safe Work Method Statement

Page 6 of 6

Safe Work Method Statement Title: SWMS: 011 INSTALLATION OF SUBMAINS

This SWMS has been developed in consultation and cooperation with employee / workers and relevant employer / persons conducting business or undertaking PCBU. I have read the above SWMS and I understand its contents. I confirm that I have the skills and training, including relevant certification to conduct the task as described. I agree to comply with safety requirements within this SWMS including risk control measures, safe work instructions and Personal Protective Equipment.

OVERALL RISK RATING AFTER CONTROLS	□ 1 LOW	□ 2 MODERATE	□ 3 HIG	Н	□ 4 ACUTE
EMPLOYEE / WORKER NAME	JOB ROLE / POSITION	SIGNATURE	DATE	EMPLOYER / PCBU / SUPERVISOR	